



Passirano, the 1st of September 2015

TO: OPREMA UREDAJI D.D.
KOPRIVNICKA 23
LUBBREG
CROATIA

LETTERA N. OPREMA/01/15

RIF.: Compatibility and explosion pressures declaration.

Dear Sirs,

we declare that our copper tubes supplied to our Customer OPREMA UREDAJI D.D. are compatible with all the refrigerant fluids present in the market, including R744 – CO2 refrigerant.

Here below the table with the explosion pressures for the dimensions supplied to OPREMA.

OD	WT	EXPLOSION PRESSURE
in mm	in mm	in BAR
12,00	0,750	281
18,00	0,750	187
10,00	0,600	269
9,52	0,600	283
6,00	1,000	748
8,00	0,600	337

FEINROHREN SpA
Luca Zanetti – Commercial Technician

A blue ink handwritten signature of Luca Zanetti.



Naturally dynamic

Feinrohren S.p.A.
Head Office
Via Generale Reverberi n. 8
25050 Passirano (BS)
Tel. 0039 030 6549011
Fax 0039 030 6549300
info@feinrohren.it
www.feinrohren.it